



ASSESSMENT No AS-10-01-Lethe(1e) TO TEST REPORT GV99.56.1

TRADE NAME: **B-15 INSPECTION DOOR LM25-ID-B15**

MANUFACTURER **LETHE GmbH**
Seehafenstrasse 17, 21079 Hamburg

The inspection door LM25-ID-B15 (constructed as described in the test report GV99.56.1) has passed the fire test for an B-15 class door according to the IMO Res. MSC 61(67) – FTP Code / Part 3) and IMO MSC/Circ. 1120. The opening of the door was 550 x 1780 mm.

We are the opinion, that an similar constructed inspection door LM25-ID2-B15 with the same light opening of 550 x 1780 mm will pass also the fire test.

Therefore the inspection door LM25-ID2-B15 built according to the attached drawings (LM25-ID2-B15 10... 15) may be regarded as B-15 class door.

Hamburg, 02 February 2010

Head of Laboratory

Dr. Eugen Rosenfeld

